



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Barnegat Twp. Schools - Collins School, 570 Barnegat Blvd.
PAS Project ID : P17-1366

Matrix : Drinking Water
Report Date : 4/6/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1366-01	FIELD BLANK COLLINS SCHOOL	Lead	0.519 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:44	3/31/17 14:26
P17-1366-02	CS1DW WC	Lead	1.35 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:45	3/31/17 14:31
P17-1366-03	CS2DW WC	Lead	0.796 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:46	3/31/17 14:39
X P17-1366-04	CS3KC	Lead	17.1	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	3/27/17 06:49	3/31/17 15:19
P17-1366-05	CS4FP 225	Lead	2.18	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 06:52	3/31/17 14:56
P17-1366-06	CS5DW	Lead	1.90 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 06:54	3/31/17 15:24
P17-1366-07	CS5DW	Lead	3.56	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 06:55	3/31/17 15:28
P17-1366-08	CS10YL 243	Lead	2.18	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 06:58	3/31/17 15:32
P17-1366-09	CS11NS	Lead	1.35 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:01	3/31/17 15:36
X P17-1366-10	CS12FP	Lead	23.2	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	3/27/17 07:03	3/31/17 16:35
P17-1366-11	CS13DW	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:05	3/31/17 15:45
P17-1366-12	CS14DW	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:06	3/31/17 15:49
P17-1366-13	CS15DW	Lead	0.519 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:08	3/31/17 15:53
P17-1366-14	CS16DW	Lead	0.796 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:09	3/31/17 16:13
P17-1366-15	CS17DW	Lead	1.35 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:10	3/31/17 16:18
P17-1366-16	CS18FP 200	Lead	1.63 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:11	3/31/17 16:26
P17-1366-17	CS19FP KETTLE (ADD)	Lead	7.16	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/27/17 07:18	3/31/17 16:31

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- g = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMBS RIVER, NJ 08725 PHONE 732-914-1515 FAX 732-914-1618

CHAIN OF CUSTODY

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 269-4204

School Name: Summit Twp Schools Collins School
 School Address: 3708 Burwood Blvd
 Sampled By: [Signature]
 Print Name: S. Bermano
 RESULTS TO: SEC Inc.

Sample ID	Location	Date - Time Sampled	Matrix Code	Grab or Comp	Filter Sample	Filter Percent	# Containers	Class or Plastic	Analysis Is	LAB ID
	Field Blank	6:45	DW	Grab			1	250 ml Plastic	Lead	P17-1366-01
1	CS1 DW WC	6:45	DW	Grab			1	250 ml Plastic	Lead	-02
2	CS2 DW WC	6:45	DW	Grab			1	250 ml Plastic	Lead	-03
3	CS3 KC	6:45	DW	Grab			1	250 ml Plastic	Lead	-04
4	CS4 FP 225	6:45	DW	Grab			1	250 ml Plastic	Lead	-05
5	CS5 DW	6:45	DW	Grab			1	250 ml Plastic	Lead	-06
6	CS6 DW	6:45	DW	Grab			1	250 ml Plastic	Lead	-07
7	CS7 DW (out of service)	7:01	DW	Grab			1	250 ml Plastic	Lead	N/A
8	CS8 DW Gym (out of service)	7:03	DW	Grab			1	250 ml Plastic	Lead	N/A
9	CS9 DW Gym (out of service)	7:03	DW	Grab			1	250 ml Plastic	Lead	N/A
10	CS10 TL 243	6:50	DW	Grab			1	250 ml Plastic	Lead	-08
11	CS11 NS	7:01	DW	Grab			1	250 ml Plastic	Lead	-09
12	CS12 FP	7:03	DW	Grab			1	250 ml Plastic	Lead	-10
13	CS13 DW	7:03	DW	Grab			1	250 ml Plastic	Lead	V -11
14	CS14 DW	7:06	DW	Grab			1	250 ml Plastic	Lead	P17-1366-12

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

All First Draw

PDF Std. PDF Reduc. PDF Full EDD
 Date/Time Preserved with label: 3/29/17 09:17

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESR 0 = No 1 = No
 WATVE 2 = H2SO4 3 = HNO3
 CODES 4 = H2O2 5 = Other

Print Name:	Signature:	Company:	Date + Time
Relinquished: <u>S. Bermano SEC Inc.</u>	<u>[Signature]</u>	PAS	3/29/17 8:30 am
Received: <u>LYAN Souza</u>			
Relinquished:			
Received:			
Relinquished:			
Received:			



Specialists In Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2101 WHITESVILLE ROAD TOMBS RIVER, NJ 08765 PHONE 732-914-1515 FAX 732-914-1616

CHAIN OF CUSTODY

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 259-4204

School Name: Burnt Boat Top School
Collins School
 School Address: 570 Burnt Boat Blvd
 Sampled By: [Signature]
 Print Name: J. Spavento
 RESULTS TO: SEL Inc.

Sample ID	Location	Date Sampled	Time Sampled	Matrix Code	Grab or Comp	Flask Type	Filter Used	# Containers	Glass or Plastic	Analysis Is	LAB ID
15	CS15 DW	7:08	am	DW	Grab			1	250 ml Plastic	Lead	P17-1366-13
16	CS16 DW	7:09	am	DW	Grab			1	250 ml Plastic	Lead	-14
17	CS17 DW	7:10	am	DW	Grab			1	250 ml Plastic	Lead	-15
18	CS18 FP 200	7:11	am	DW	Grab			1	250 ml Plastic	Lead	↓ -16
19	CS19 FP Kettle (Add)	7:18	am	DW	Grab			1	250 ml Plastic	Lead	P17-1366-17
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	
				DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.
 All First Draw
 Page 2 of 2

PDF Std. PDF Reduc. PDF Full EDD
 Date/Time Preserved with (MDD): 3/29/17 @ 09:12

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PREER 0 = Ice 1 = HCl
 VATIVE 2 = H2SO4 3 = NaOH
 CODES: 4 = HNO3 5 = Other

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Relinquished:	J. Spavento	[Signature]	PAS	3/29/17 8:30 am
Received:	Lynn Souza	[Signature]		
Relinquished:				
Received:				
Relinquished:				
Received:				