



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Barnegat Twp. Schools - Dunfee Elementary, 128 Barnegat Blvd.
PAS Project ID : P17-1365

Matrix : Drinking Water
Report Date : 4/6/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1365-01	FIELD BLANK DUNFEE ELEMENTARY	Lead	0.519 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 05:50	3/31/17 10:19
P17-1365-02	DE1KC	Lead	2.73	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 05:52	3/31/17 10:23
P17-1365-03	DE2KC	Lead	2.18	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 05:54	3/31/17 10:31
P17-1365-04	DE3DW WC	Lead	0.796 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 05:57	3/31/17 12:56
P17-1365-05	DE5DW WC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:01	3/31/17 13:00
P17-1365-06	DE6DW WC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:02	3/31/17 13:04
P17-1365-07	DE7FP 100	Lead	5.78	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:04	3/31/17 13:08
P17-1365-08	DE8FP 101	Lead	16.5	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	3/29/17 06:05	3/31/17 13:13
P17-1365-09	DE9FP 102	Lead	4.39	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:08	3/31/17 13:17
P17-1365-10	DE10FP MAIN OFFICE	Lead	2.46	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:11	3/31/17 13:21
P17-1365-11	DE11FP TL	Lead	1.35 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:13	3/31/17 13:34
P17-1365-12	DE12 DW	Lead	3.01	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:15	3/31/17 13:38
P17-1365-13	DE13DW WC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:16	3/31/17 13:43
P17-1365-14	DE14DW WC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:17	3/31/17 13:47
P17-1365-15	DE15DW	Lead	2.46	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:20	3/31/17 13:52
P17-1365-16	DE16DW WC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:21	3/31/17 13:56
P17-1365-17	DE17DW WC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:22	3/31/17 14:00
P17-1365-18	DE18NS 126	Lead	0.796 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:26	3/31/17 14:05
P17-1365-19	DE19DW WC	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:28	3/31/17 14:09
P17-1365-20	DE20DW WC	Lead	0.519 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/29/17 06:29	3/31/17 14:22

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- B = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists In Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

PRECISION ANALYTICAL SERVICES, INC.

2101 WHITEVILLE ROAD TOMS RIVER, NJ 08754 PHONE 732-616-1515 FAX 732-614-1610

CHAIN OF CUSTODY

School Name: Brueggert Top Schools Justice Elementary
 School Address: 125 Brueggert Blvd
 Sampled By: [Signature]
 Print Name: J. Romano
 RESULTS TO: SEC Inc.

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 269-4204

Sample ID Location	Date Sampled	Matrix Code	Grab or Comp	Thick Sample	Filter Present	# Containers	Glass or Plastic	Analysis Is	LAB ID
Field Blank Justice Elem.	5:30	DW	Grab			1	250 ml Plastic	Lead	P17-1365-01
1 DE 1 KC	5:33	DW	Grab			1	250 ml Plastic	Lead	-02
2 DE 2 KC	5:35	DW	Grab			1	250 ml Plastic	Lead	-03
3 DE 3 DW WC	5:37	DW	Grab			1	250 ml Plastic	Lead	-04
4 DE 4 DW (out of service)	5:39	DW	Grab			1	250 ml Plastic	Lead	N/A
5 DE 5 DW WC	5:41	DW	Grab			1	250 ml Plastic	Lead	-05
6 DE 6 DW WC	5:43	DW	Grab			1	250 ml Plastic	Lead	-06
7 DE 7 FP 100	5:45	DW	Grab			1	250 ml Plastic	Lead	-07
8 DE 8 FP 101	5:47	DW	Grab			1	250 ml Plastic	Lead	-08
9 DE 9 FP 102	5:49	DW	Grab			1	250 ml Plastic	Lead	-09
10 DE 10 FP main office	5:51	DW	Grab			1	250 ml Plastic	Lead	-10
11 DE 11 F P TL	5:53	DW	Grab			1	250 ml Plastic	Lead	-11
12 DE 12 DW	5:55	DW	Grab			1	250 ml Plastic	Lead	-12
13 DE 13 DW WC	5:57	DW	Grab			1	250 ml Plastic	Lead	✓ -13
14 DE 14 DW WC	6:00 am	DW	Grab			1	250 ml Plastic	Lead	P17-1365-14

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

All First Draw

PDF Std. PDF Reduc PDF Full EDD

Date/Time Preserved with (DOB): 3/29/17 @ 09:12

Page 1 of 2 Deliverables: X

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify)

PREP: 0 = low 1 = HI
 VATIVE: 2 = H2O4 3 = FACI
 CODES: 4 = RH03 5 = ODR

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Relinquished:	J. Romano	[Signature]	PAS	3/29/17 8:30am
Received:	LYAN Souza	[Signature]		
Relinquished:				
Received:				
Relinquished:				
Received:				



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08725 PHONE 732-614-1815 FAX 732-614-1816

CHAIN OF CUSTODY

Burgess Top Schools
Dandel Elementary

School Name:

School Address:

Sampled By:

Print Name:

RESULTS TO:

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 269-4204

1283 Burgess Blvd
 S. [Signature]
 SEL Inc.

Sample ID	Location	Date Sampled	Matrix Code	Grab or Comp	Flow Sample	Flow Protect	# Containers	Glass or Plastic	Analysis	LAB ID
15	DE 15 DW	6/20/17	DW	Grab			1	250 ml Plastic	Lead	D17-1365-15
16	DE 16 DW WC	6/21/17	DW	Grab			1	250 ml Plastic	Lead	-16
17	DE 17 DW WC	6/21/17	DW	Grab			1	250 ml Plastic	Lead	-17
18	DE 18 NS 126	6/21/17	DW	Grab			1	250 ml Plastic	Lead	-18
19	DE 19 DW WC	6/21/17	DW	Grab			1	250 ml Plastic	Lead	V -19
20	DE 20 DW WC	6/21/17	DW	Grab			1	250 ml Plastic	Lead	D17-1365-20
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	

All First Draw

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. PDF Reduc. PDF Full EDD Date/Time received with fees: 3/29/17 @ 09:12

Page 2 of 2

Deliverables: X

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PREP: 0 = Ice, 1 = IIC
 VATIVE: 2 = H2SO4, 3 = HNO3
 CODES: 4 = H2O2, 5 = Other

	Print Name:	Signature:	Date & Time
Relinquished:	S. [Signature] SEL Inc.	[Signature]	3/29/17 9:30 am
Received:	Lynn Souza	[Signature]	
Relinquished:			
Received:			
Relinquished:			
Received:			